



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert No. GYJ23.1105X

Manufacturer Primoflo (Shanghai) Co., Ltd.
(Address: 2F, Building 7, No.3255, Shengang Road, Songjiang District, Shanghai, China)

Product Solenoid Valves

Model RSC/RHC Series

Ex marking Ex db IIC T6...T4/T3 Gb
Ex tb IIIC T85°C...T135°C/T150°C Db

Product standard /
RHC-00001-01 Rev.A, RSC-00002-01 Rev.A
001-00084/ 00085-01 Rev.A, 001-00092/ 00093-01 Rev.A
010-00076 / 00077 / 00078-01 Rev.A, 010-00088 / 00089 /
00090-01 Rev.A

Drawing number 069-00084 / 00085-01 Rev.A, 069-00092 / 00093-01 Rev.A
086-00073 / 00074 / 00075-01 Rev.A, 086-00085 / 00086 /
00087-01 Rev.A

The product was found to comply with the following standard(s):

GB/T 3836.1-2021,GB/T 3836.2-2021,GB/T 3836.31-2021

Valid until: 2028.09.07

Remarks

- 1.Conditions for safe use are specified in the attachment(s) to this certificate.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use , which are specified in the attachment(s) to this certificate.
- 3.Model designation is specified in the attachment(s) to this certificate.
- 4.Safe parameters specified in the attachment(s) to this certificate.



Approval

Shanghai Inspection and Testing Institute of
Instruments and Automation Systems Co., Ltd.
National Supervision and Inspection Center for
Explosion Protection and Safety of Instrumentation
Date of issue 2023.09.08

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.